

**CONFORMITY TO TYPE BASED ON INTERNAL PRODUCTION CONTROL PLUS SUPERVISED
PRODUCT CHECKS AT RANDOM INTERVALS (MODULE C2)**

**MODÜL C2 - ÜRETİMİN DÂHİLİ KONTROLÜ VE ÜRÜNÜN RASTGELE
ARALIKLARLA DENETİMLİ MUAYENESİNE DAYALI TİPE UYGUNLUK**

Belge No / Certificate No : 253-21-01-01
**Belgelendirme Tarihi - Bir Sonraki Belge Tarihi /
Certification Date / Certificate Validity Date** : 01.02.2022-01.02.2023
Belge Geçerlilik Tarihi / Document Validity Period : 1 yıl / 1 year
**Firma Unvanı ve Adresi /
Company Name and Address** : ANKA PROMOSYON ÜRÜNLERİ VE
MATBAA MALZEMELERİ SANAYİ TİCARET
LİMİTED ŞİRKETİ
Fevzi Çakmak Mah. 10576. Sk. No: 66/D , 42050
Karatay/KONYA
Ürün Adı /Modeller / Product Name / Models : DM-33
Direktifi / Directive : 2016/425 REGULATION
Modülü/Kategori / Module / Category : C2 MODÜLÜ/ KATEGORİ III
MODULE C2 / CATEGORY III
**Teknik Değerlendirme Rapor No/
Technical Evaluation Report No** : MNA 253-21-01-01
Ürün Tipi / Product Type:
- EN 149:2001+ A1:2009 Solunumla ilgili koruyucu cihazlar- Parçacıklara karşı koruma amaçlı filtreli
yarım maskeler/ Respiratory protective devices - Filtering half masks to protect against particles

Ürünün Malzeme Bilgisi / Product Material Information: DM-33 model ürünleri kumaş, elastik kayış, burun
klipsi, filtre katmanı kullanılarak imal edilmiştir. / DM-33 products are manufactured using fabric, elastic
strap, nose clip, filter layer.


Volkan AKIN
01.02.2022

Karar Verici / Approver



Okan AKEL
01.02.2022

Şirket Müdürü / General manager



Report No : 253-21-01-01

Report Date : 01.02.2022

Application No : 253-21-01-01

1. COMPANY INFORMATION:

ANKA PROMOSYON ÜRÜNLERİ VE MATBAA MALZEMELERİ SANAYİ TİCARET LİMİTED ŞİRKETİ
Fevzi Çakmak Mah. 10576. Sk. No: 66/D , 42050 Karatay/KONYA


2. PPE INFORMATION:

Disposable and non-sterile half mask made of particulate protection filter material.

3. PPE TYPE IDENTIFICATION

EN 149:2001+A1:2009 Respiratory protective devices – Filtering half masks to protect against particles - Requirements, testing, marking

4. PPE PICTURES



DM-33

5. PPE DIMENSIONS:

DM-33 model has been found to be produced using standard sizes.

6. PPE PRODUCT MATERIAL INFORMATION:

The mask is made of elastic strap, nonwoven fabric on the outer and inner layers and filter material on the middle layer.

7. ESSENTIAL HEALTH AND SAFETY REQUIREMENTS

- A visual inspection was made according to EN 149:2001 +A1:2009 for ergonomics.
- Protection levels and degrees are defined by the manufacturer.

**mna**

**CONFORMITY TO TYPE BASED ON INTERNAL
PRODUCTION CONTROL PLUS SUPERVISED PRODUCT
CHECK AT RANDOM INTERVALS
(MODULE C2, ANNEX VII) (253-21-01-01)**

Notified Body Number: 2841

- Suitable construction materials were determined by visual inspection according to EN 149:2001 +A1:2009.

8. ANALYSIS AND EVALUATIONS:

EN 149:2001 +A1:2009

TESTS	PARAMETER	PERFORMANCE LEVELS			RESULTS	PERFORMANCE LEVELS	EVALUATION
		FFP1	FFP2	FFP3			
Banned Azo Dyes	< 30 mg/kg				-	-	Not applicable
Part 7.3 Visual inspection	Shall also the marking and the information supplied by the manufacturer				Appropriate	-	PASS
Part 7.4 Packaging	Particle filtering half mask shall be offered for sale packaged in such a way that they are protected against mechanical damage and contamination before use.				Appropriate	-	PASS
Part 7.5 Material	When conditioned in accordance 8.3.1 & 8.3.2 the particle filter half mask shall not collapse.				Appropriate	-	PASS
Part 7.6 Cleaning and disinfecting	After cleaning and disinfecting the re-usable particle filtering half mask shall satisfy the penetration requirement of the relevant class.				Not applicable	-	Not applicable
Part 7.7 Practical performance	No negative comments should be made by the test subject regarding any of the criteria evaluated.				Appropriate	-	PASS
Part 7.8 Finish of parts	Parts of the device likely to come into contact with the wearer shall have no sharp edge or burrs.				Appropriate	-	PASS

TESTS	PARAMETER	PERFORMANCE LEVELS			RESULTS	PERFORMANCE LEVELS	EVALUATION
		FFP1	FFP2	FFP3			
Part 7.9.1 Total inward leakage	At least 46 out of the 50 individual exercise result	<25	<11	<5	See the table below	FFP2	PASS
	At least 8 out of the 10 individual wearer arithmetic means	<22	<8	<2	See the table below	FFP2	PASS

Total Inward Leakage (%)						
	Exercise 1	Exercise 2	Exercise 3	Exercise 4	Exercise 5	Average
Subject 1 (As received)	4,4	5,5	5,4	6,3	5,4	5,4
Subject 2 (As received)	4,7	5,0	6,0	4,2	4,0	4,8
Subject 3 (As received)	5,2	4,7	5,8	2,6	4,7	4,6
Subject 4 (As received)	6,3	6,7	4,6	4,5	6,3	5,7

**CONFORMITY TO TYPE BASED ON INTERNAL
PRODUCTION CONTROL PLUS SUPERVISED PRODUCT
CHECK AT RANDOM INTERVALS
(MODULE C2, ANNEX VII) (253-21-01-01)**

Subject 5 (As received)	6,5	3,7	5,8	5,6	4,0	5,1
Subject 6 (After temperature conditioning)	5,9	6,3	3,5	3,7	5,7	5,0
Subject 7 (After temperature conditioning)	6,1	6,9	5,7	5,7	6,0	6,1
Subject 8 (After temperature conditioning)	5,4	5,7	6,9	7,5	4,7	6,0
Subject 9 (After temperature conditioning)	5,3	5,5	5,4	5,4	5,3	5,4
Subject 10 (After temperature conditioning)	6,1	5,3	5,1	6,1	3,4	5,2

Subject facial dimensions

Subject	Face Length (mm)	Face Width (mm)	Face Depth (mm)	Mouth Width (mm)
1	133	132	132	65
2	125	144	116	67
3	126	135	124	75
4	123	133	134	74
5	117	135	122	73
6	122	142	133	66
7	113	132	114	75
8	135	123	123	65
9	122	135	133	74
10	135	142	125	83

TESTS	PARAMETER	PERFORMANCE LEVELS			RESULTS	PERFORMANCE LEVELS	EVALUATION
		FFP1	FFP2	FFP3			
Part 7.9.2 Penetration of filter material	Sodium chloride, 95 L/min % max	% 20	% 6	% 1	See the table below	FFP2	PASS
	Paraffin oil, 95 L/min % max	% 20	% 6	% 1	See the table below	FFP2	PASS

Penetration of filter material	Sodium Chloride (%)	Paraffin Oil (%)
As received	2,5	2,6
As received	2,2	2,6
As received	2,4	2,7
After the simulated wearing treatment	2,4	2,4
After the simulated wearing treatment	2,6	2,8
After the simulated wearing treatment	2,3	2,6
Mechanical strength and temperature conditioning	3,9	4,1
Mechanical strength and temperature conditioning	3,5	4,0
Mechanical strength and temperature conditioning	3,6	4,1

TESTS	PARAMETER	PERFORMANCE LEVELS			RESULTS	PERFORMANCE LEVELS	EVALUATION
		FFP1	FFP2	FFP3			

**CONFORMITY TO TYPE BASED ON INTERNAL
PRODUCTION CONTROL PLUS SUPERVISED PRODUCT
CHECK AT RANDOM INTERVALS
(MODULE C2, ANNEX VII) (253-21-01-01)**

Part 7.10 Compatibility with skin	Materials shall not be known to be likely to cause irritation or any other adverse effect to health	Appropriate	-	PASS
Part 7.11 Flammability	Mask shall not burn or not to continue to burn for more than 5 s	Flame not seen	-	PASS
Part 7.12 Carbondioxide content of the inhalation air	Shall not exceed an average of % 1	0,75 0,79 0,70	-	PASS
Part 7.13 Head harness	It can be donned and removed easily	Appropriate	-	PASS
Part 7.14 Field of vision	The field of vision shall acceptable in practical performance test.	Appropriate	-	PASS
Part 7.15 Exhalation valve(s)	It shall withstand axially a tensile force of 10 N apply for 10 s. If fitted, shall continue to operate correctly after a continuous exhalation flow of 300 L/min over a period of 30 s.	Not applicable	-	Not applicable

TESTS	PARAMETER	PERFORMANCE LEVELS			RESULTS	PERFORMANCE LEVELS	EVALUATION
		FFP1	FFP2	FFP3			
Part 7.16 Breathing Resistance	Inhalation 30L/min	0,6 mbar	0,7 mbar	1,0 mbar	See the table below	FFP2	PASS
	Inhalation 95L/min	2,1 mbar	2,4 mbar	3,0 mbar	See the table below	FFP2	PASS
	Exhalation 160L/min	3,0 mbar	3,0 mbar	3,0 mbar	See the table below	FFP2	PASS

Breathing Resistance (mbar)		Inhalation 30L/min	Inhalation 95L/min
As received		0,5	1,6
As received		0,5	1,7
As received		0,4	1,6
After temperature conditioning		0,4	1,6
After temperature conditioning		0,4	1,6
After temperature conditioning		0,5	1,7
After the simulated wearing treatment		0,5	1,7
After the simulated wearing treatment		0,4	1,6
After the simulated wearing treatment		0,5	1,7

Breathing Resistance 160L/min (mbar)	Facing directly ahead	Facing vertically upwards	Facing vertically downwards	Lying on the left side	Lying on the right side
As received	2,7	2,6	2,7	2,7	2,6
As received	2,6	2,7	2,6	2,6	2,6
As received	2,7	2,6	2,6	2,6	2,6
After temperature conditioning	2,6	2,7	2,7	2,7	2,7
After temperature conditioning	2,6	2,7	2,7	2,7	2,7
After temperature conditioning	2,6	2,6	2,6	2,6	2,6

**mna****CONFORMITY TO TYPE BASED ON INTERNAL
PRODUCTION CONTROL PLUS SUPERVISED PRODUCT**

Notified Body Number: 2841

**CHECK AT RANDOM INTERVALS
(MODULE C2, ANNEX VII) (253-21-01-01)**

After the simulated wearing treatment	2,7	2,6	2,6	2,6	2,6
After the simulated wearing treatment	2,6	2,7	2,7	2,7	2,7
After the simulated wearing treatment	2,7	2,6	2,6	2,6	2,6

TESTS	PARAMETER	PERFORMANCE LEVELS			RESULTS	PERFORMANCE LEVELS	EVALUATION
		FFP1	FFP2	FFP3			
Part 7.17 Clogging	After clogging the inhalation resistances shall not exceed. (valved)	4 mbar	5 mbar	7 mbar	Not applicable	-	Not applicable
	The exhalation resistance shall not exceed 3 mbar at 160 L/ min continuous flow. (valved)				Not applicable	-	Not applicable
	After clogging the inhalation and exhalation resistances shall not exceed. (valveless)	3 mbar	4 mbar	5 mbar	Not applicable	-	Not applicable
Part 7.18 Demountable part	All demountable parts (if fitted) shall be readily connected and secured were possible by hand.				Not applicable	-	Not applicable

9. DECISION

Analysis and examinations DM-33 model coded personal protective equipment; Respiratory Protective Devices EN 149:2001 +A1:2009- Filtered Half Masks for Protection Against Particles - Properties, Experiments and Marking standards are evaluated. The homogeneity of the production was monitored at the performance levels determined as a result of the technical evaluations made within the scope of MODULE C2.

10. ATTACHMENTS

- Basic Health Safety Requirements
- Risk Assessment
- Test Reports (M-2022-0121)
- User Instruction

CONTROLLER : Volkan AKIN**SIGNATURE** :**DATE** : 01.02.2022

EC DECLARATION OF CONFIRMITY

ANKA PROMOSYON ÜRÜNLERİ VE MATB. MALZ. SAN. TİC. LTD. ŞTİ.
FEVZİ ÇAKMAK MAH.10576 SK.NO:66/D 42050 KARATAY/KONYA

Product Definition : Protective Mask

Brand Name : DOST

Model : DM-33

Classification : FFP2 NR

Barcode Number : 8682759618174

To which this declaration relates are in conformity with the requirements of the following directives;

Personal Protective Equipment Regulation (EU) 2016/425 Annex III

We are declaring our product suitable for European conditions and accepting all responsibilities about our product. The conformity was checked for Personal Protective Equipment Regulation in accordance with the following harmonized EN standard.

EN 149:2001 + A1:2009

The EU type examination document has been issued by MNA LABORATORIES with the Notified Body Number: 2841. Codes of the analysis reports of the products M-2021-01006. The number of the EU Type Examination document is 253-21-01 in addition, since the product is in category III group, the process monitoring is provided by MNA LABORATORIES for the internal control of the product production and the evaluation of the product within the scope of conformity to type (Module C2) based on supervised inspection at random intervals.

Person responsible for making this declaration

Name, Surname : Yasin Emre Yıldırım

Position : General Manager

Date : 28.05.2021

CE
2841



ANKA PROMOSYON ÜRÜNLERİ ve
MATBAA MALZ. SAN. TİC. LTD. ŞTİ.
Saklık Yö. 679 BİRİM 1024 - Tic.Sic: 52993
Fevzi Çakmak Mah. 10576 Sk. No: 66/D
Karatay / KONYA Tel: 0 332 345 00 10